
June 20, 2017

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:

MILL HILL ES

MAIN

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
7858255	CONFERENCE	2017-06-12 @ 9:00 am	2017-06-15 @ 9:00 am	0.9 ± 0.3	2017-06-19
7858258	ROOM 10	2017-06-12 @ 9:00 am	2017-06-15 @ 9:00 am	0.6 ± 0.3	2017-06-19
7858256	ROOM 11	2017-06-12 @ 9:00 am	2017-06-15 @ 9:00 am	< 0.3	2017-06-19
7858253	ROOM 14	2017-06-12 @ 9:00 am	2017-06-15 @ 9:00 am	< 0.3	2017-06-19
7858254	ROOM 14	2017-06-12 @ 9:00 am	2017-06-15 @ 9:00 am	0.7 ± 0.3	2017-06-19
7858257	ROOM 9	2017-06-12 @ 9:00 am	2017-06-15 @ 9:00 am	< 0.3	2017-06-19

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

June 20, 2017

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:
RIVERFIELD ES
MAIN

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
7858259	GYM OFFICE	2017-06-12 @ 10:00 am	2017-06-15 @ 10:00 am	0.6 ± 0.3	2017-06-19
7858260	GYM OFFICE	2017-06-12 @ 10:00 am	2017-06-15 @ 10:00 am	< 0.3	2017-06-19

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498