



ENVIRONMENTAL, LLC

May 11, 2015

Mr. Sal Morabito
Fairfield Public Schools
501 Kings Highway East
Fairfield, CT 06824

RE: Osborn Hill School PCB Wipe Results – Gymnasium

Dear Mr. Morabito:

AMC Environmental obtained wipe samples from the Gymnasium at Osborn Hill Elementary School on May 6, 2015. The wipes were obtained after the installation of the new gym equipment and cleaning to confirm acceptable levels of PCBs for dermal contact. The new equipment was installed over encapsulated PCB materials. The wipe sampling was performed after the limited PCB disturbance to verify the cleanliness of the gymnasium following the installation of the equipment.

AMC obtained sixteen (16) wipe samples from the walls and floor of the gymnasium as well as two (2) blanks. All samples were documented to contain <1 ppm PCB and therefore are considered acceptable. No further testing is required at this time.

If you have any questions please do not hesitate to contact our office.

Sincerely,

Jason Pringle

AMC
Environmental,
LLC

Phone:
203.378.5020

Fax:
203.375.7344

Email:
amc@amcenviro.com

P.O Box 423
Stratford, CT
06615

May 11, 2015

Jason Pringle
AMC Environmental, LLC
PO Box 423
Stratford, CT 06615

Project Location: Osborn - Gymnasium
Client Job Number:
Project Number: [none]
Laboratory Work Order Number: 15E0302

Enclosed are results of analyses for samples received by the laboratory on May 7, 2015. If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Steven M. Case
Project Manager

Table of Contents

Sample Summary	4
Case Narrative	5
Sample Results	6
15E0302-01	6
15E0302-02	7
15E0302-03	8
15E0302-04	9
15E0302-05	10
15E0302-06	11
15E0302-07	12
15E0302-08	13
15E0302-09	14
15E0302-10	15
15E0302-11	16
15E0302-12	17
15E0302-13	18
15E0302-14	19
15E0302-15	20
15E0302-16	21
Sample Preparation Information	22
QC Data	23
Polychlorinated Biphenyls with 3540 Soxhlet Extraction	23
B121329	23
Dual Column RPD Report	24
Flag/Qualifier Summary	27
Certifications	28

Table of Contents (continued)

Chain of Custody/Sample Receipt

29

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

AMC Environmental, LLC
 PO Box 423
 Stratford, CT 06615
 ATTN: Jason Pringle

REPORT DATE: 5/11/2015

PURCHASE ORDER NUMBER:

PROJECT NUMBER: [none]

ANALYTICAL SUMMARY

WORK ORDER NUMBER: 15E0302

The results of analyses performed on the following samples submitted to the CON-TEST Analytical Laboratory are found in this report.

PROJECT LOCATION: Osborn - Gymnasium


FIELD SAMPLE #	LAB ID:	MATRIX	SAMPLE DESCRIPTION	TEST	SUB LAB
PCB-W-01 - Side A Wall	15E0302-01	Wipe		SW-846 8082A	
PCB-W-02 - Side A Wall	15E0302-02	Wipe		SW-846 8082A	
PCB-W-03 - Side B Wall	15E0302-03	Wipe		SW-846 8082A	
PCB-W-04 - Side B Wall	15E0302-04	Wipe		SW-846 8082A	
PCB-W-05 - Side C Wall	15E0302-05	Wipe		SW-846 8082A	
PCB-W-06 - Side C Wall	15E0302-06	Wipe		SW-846 8082A	
PCB-W-07 - Side D Wall	15E0302-07	Wipe		SW-846 8082A	
PCB-W-08 - Side D Wall	15E0302-08	Wipe		SW-846 8082A	
PCB-W-09 - Floor	15E0302-09	Wipe		SW-846 8082A	
PCB-W-10 - Floor	15E0302-10	Wipe		SW-846 8082A	
PCB-W-11 - Floor	15E0302-11	Wipe		SW-846 8082A	
PCB-W-12 - Floor	15E0302-12	Wipe		SW-846 8082A	
PCB-W-13 - Floor	15E0302-13	Wipe		SW-846 8082A	
PCB-W-14 - Floor	15E0302-14	Wipe		SW-846 8082A	
PCB-W-15 - Blank	15E0302-15	Wipe		SW-846 8082A	
PCB-W-16 - Blank	15E0302-16	Wipe		SW-846 8082A	

CASE NARRATIVE SUMMARY

All reported results are within defined laboratory quality control objectives unless listed below or otherwise qualified in this report.

The results of analyses reported only relate to samples submitted to the Con-Test Analytical Laboratory for testing.

I certify that the analyses listed above, unless specifically listed as subcontracted, if any, were performed under my direction according to the approved methodologies listed in this document, and that based upon my inquiry of those individuals immediately responsible for obtaining the information, the material contained in this report is, to the best of my knowledge and belief, accurate and complete.

A photograph of a handwritten signature in black ink on a light-colored background. The signature is written in a cursive style and reads "Johanna K. Harrington".

Johanna K. Harrington
Manager, Laboratory Reporting

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: Osborn - Gymnasium

Sample Description:

Work Order: 15E0302

Date Received: 5/7/2015

Field Sample #: PCB-W-01 - Side A Wall

Sampled: 5/6/2015 00:00

Sample ID: 15E0302-01

Sample Matrix: Wipe

Polychlorinated Biphenyls with 3540 Soxhlet Extraction

Analyte	Results	RL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Aroclor-1016 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 18:03	KAL
Aroclor-1221 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 18:03	KAL
Aroclor-1232 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 18:03	KAL
Aroclor-1242 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 18:03	KAL
Aroclor-1248 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 18:03	KAL
Aroclor-1254 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 18:03	KAL
Aroclor-1260 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 18:03	KAL
Aroclor-1262 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 18:03	KAL
Aroclor-1268 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 18:03	KAL
Surrogates		% Recovery	Recovery Limits		Flag/Qual				
Decachlorobiphenyl [1]		90.4	30-150					5/9/15 18:03	
Decachlorobiphenyl [2]		88.5	30-150					5/9/15 18:03	
Tetrachloro-m-xylene [1]		83.8	30-150					5/9/15 18:03	
Tetrachloro-m-xylene [2]		85.5	30-150					5/9/15 18:03	

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: Osborn - Gymnasium

Sample Description:

Work Order: 15E0302

Date Received: 5/7/2015

Field Sample #: PCB-W-02 - Side A Wall

Sampled: 5/6/2015 00:00

Sample ID: 15E0302-02

Sample Matrix: Wipe

Polychlorinated Biphenyls with 3540 Soxhlet Extraction

Analyte	Results	RL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Aroclor-1016 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 18:16	KAL
Aroclor-1221 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 18:16	KAL
Aroclor-1232 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 18:16	KAL
Aroclor-1242 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 18:16	KAL
Aroclor-1248 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 18:16	KAL
Aroclor-1254 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 18:16	KAL
Aroclor-1260 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 18:16	KAL
Aroclor-1262 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 18:16	KAL
Aroclor-1268 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 18:16	KAL
Surrogates		% Recovery	Recovery Limits		Flag/Qual				
Decachlorobiphenyl [1]		95.2	30-150					5/9/15 18:16	
Decachlorobiphenyl [2]		93.5	30-150					5/9/15 18:16	
Tetrachloro-m-xylene [1]		83.5	30-150					5/9/15 18:16	
Tetrachloro-m-xylene [2]		85.8	30-150					5/9/15 18:16	

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: Osborn - Gymnasium

Sample Description:

Work Order: 15E0302

Date Received: 5/7/2015

Field Sample #: PCB-W-03 - Side B Wall

Sampled: 5/6/2015 00:00

Sample ID: 15E0302-03

Sample Matrix: Wipe

Polychlorinated Biphenyls with 3540 Soxhlet Extraction

Analyte	Results	RL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Aroclor-1016 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 18:28	KAL
Aroclor-1221 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 18:28	KAL
Aroclor-1232 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 18:28	KAL
Aroclor-1242 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 18:28	KAL
Aroclor-1248 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 18:28	KAL
Aroclor-1254 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 18:28	KAL
Aroclor-1260 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 18:28	KAL
Aroclor-1262 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 18:28	KAL
Aroclor-1268 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 18:28	KAL
Surrogates		% Recovery	Recovery Limits		Flag/Qual				
Decachlorobiphenyl [1]		94.2	30-150					5/9/15 18:28	
Decachlorobiphenyl [2]		92.3	30-150					5/9/15 18:28	
Tetrachloro-m-xylene [1]		83.4	30-150					5/9/15 18:28	
Tetrachloro-m-xylene [2]		85.4	30-150					5/9/15 18:28	

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: Osborn - Gymnasium

Sample Description:

Work Order: 15E0302

Date Received: 5/7/2015

Field Sample #: PCB-W-04 - Side B Wall

Sampled: 5/6/2015 00:00

Sample ID: 15E0302-04

Sample Matrix: Wipe

Polychlorinated Biphenyls with 3540 Soxhlet Extraction

Analyte	Results	RL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Aroclor-1016 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 18:40	KAL
Aroclor-1221 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 18:40	KAL
Aroclor-1232 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 18:40	KAL
Aroclor-1242 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 18:40	KAL
Aroclor-1248 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 18:40	KAL
Aroclor-1254 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 18:40	KAL
Aroclor-1260 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 18:40	KAL
Aroclor-1262 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 18:40	KAL
Aroclor-1268 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 18:40	KAL
Surrogates		% Recovery	Recovery Limits		Flag/Qual				
Decachlorobiphenyl [1]		103	30-150					5/9/15 18:40	
Decachlorobiphenyl [2]		102	30-150					5/9/15 18:40	
Tetrachloro-m-xylene [1]		92.4	30-150					5/9/15 18:40	
Tetrachloro-m-xylene [2]		93.4	30-150					5/9/15 18:40	

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: Osborn - Gymnasium

Sample Description:

Work Order: 15E0302

Date Received: 5/7/2015

Field Sample #: PCB-W-05 - Side C Wall

Sampled: 5/6/2015 00:00

Sample ID: 15E0302-05

Sample Matrix: Wipe

Polychlorinated Biphenyls with 3540 Soxhlet Extraction

Analyte	Results	RL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Aroclor-1016 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 18:52	KAL
Aroclor-1221 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 18:52	KAL
Aroclor-1232 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 18:52	KAL
Aroclor-1242 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 18:52	KAL
Aroclor-1248 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 18:52	KAL
Aroclor-1254 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 18:52	KAL
Aroclor-1260 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 18:52	KAL
Aroclor-1262 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 18:52	KAL
Aroclor-1268 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 18:52	KAL
Surrogates		% Recovery	Recovery Limits		Flag/Qual				
Decachlorobiphenyl [1]		77.8	30-150					5/9/15 18:52	
Decachlorobiphenyl [2]		76.4	30-150					5/9/15 18:52	
Tetrachloro-m-xylene [1]		76.6	30-150					5/9/15 18:52	
Tetrachloro-m-xylene [2]		79.1	30-150					5/9/15 18:52	

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: Osborn - Gymnasium

Sample Description:

Work Order: 15E0302

Date Received: 5/7/2015

Field Sample #: PCB-W-06 - Side C Wall

Sampled: 5/6/2015 00:00

Sample ID: 15E0302-06

Sample Matrix: Wipe

Polychlorinated Biphenyls with 3540 Soxhlet Extraction

Analyte	Results	RL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Aroclor-1016 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 19:05	KAL
Aroclor-1221 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 19:05	KAL
Aroclor-1232 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 19:05	KAL
Aroclor-1242 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 19:05	KAL
Aroclor-1248 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 19:05	KAL
Aroclor-1254 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 19:05	KAL
Aroclor-1260 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 19:05	KAL
Aroclor-1262 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 19:05	KAL
Aroclor-1268 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 19:05	KAL
Surrogates		% Recovery	Recovery Limits		Flag/Qual				
Decachlorobiphenyl [1]		80.8	30-150					5/9/15 19:05	
Decachlorobiphenyl [2]		78.8	30-150					5/9/15 19:05	
Tetrachloro-m-xylene [1]		70.0	30-150					5/9/15 19:05	
Tetrachloro-m-xylene [2]		72.5	30-150					5/9/15 19:05	

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: Osborn - Gymnasium

Sample Description:

Work Order: 15E0302

Date Received: 5/7/2015

Field Sample #: PCB-W-07 - Side D Wall

Sampled: 5/6/2015 00:00

Sample ID: 15E0302-07

Sample Matrix: Wipe

Polychlorinated Biphenyls with 3540 Soxhlet Extraction

Analyte	Results	RL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Aroclor-1016 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 19:17	KAL
Aroclor-1221 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 19:17	KAL
Aroclor-1232 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 19:17	KAL
Aroclor-1242 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 19:17	KAL
Aroclor-1248 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 19:17	KAL
Aroclor-1254 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 19:17	KAL
Aroclor-1260 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 19:17	KAL
Aroclor-1262 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 19:17	KAL
Aroclor-1268 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 19:17	KAL
Surrogates		% Recovery	Recovery Limits		Flag/Qual				
Decachlorobiphenyl [1]		92.8	30-150					5/9/15 19:17	
Decachlorobiphenyl [2]		90.8	30-150					5/9/15 19:17	
Tetrachloro-m-xylene [1]		84.8	30-150					5/9/15 19:17	
Tetrachloro-m-xylene [2]		86.5	30-150					5/9/15 19:17	

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: Osborn - Gymnasium

Sample Description:

Work Order: 15E0302

Date Received: 5/7/2015

Field Sample #: PCB-W-08 - Side D Wall

Sampled: 5/6/2015 00:00

Sample ID: 15E0302-08

Sample Matrix: Wipe

Polychlorinated Biphenyls with 3540 Soxhlet Extraction

Analyte	Results	RL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Aroclor-1016 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 19:29	KAL
Aroclor-1221 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 19:29	KAL
Aroclor-1232 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 19:29	KAL
Aroclor-1242 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 19:29	KAL
Aroclor-1248 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 19:29	KAL
Aroclor-1254 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 19:29	KAL
Aroclor-1260 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 19:29	KAL
Aroclor-1262 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 19:29	KAL
Aroclor-1268 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 19:29	KAL
Surrogates		% Recovery	Recovery Limits		Flag/Qual				
Decachlorobiphenyl [1]		97.9	30-150					5/9/15 19:29	
Decachlorobiphenyl [2]		96.0	30-150					5/9/15 19:29	
Tetrachloro-m-xylene [1]		86.9	30-150					5/9/15 19:29	
Tetrachloro-m-xylene [2]		89.0	30-150					5/9/15 19:29	

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: Osborn - Gymnasium

Sample Description:

Work Order: 15E0302

Date Received: 5/7/2015

Field Sample #: PCB-W-09 - Floor

Sampled: 5/6/2015 00:00

Sample ID: 15E0302-09

Sample Matrix: Wipe

Polychlorinated Biphenyls with 3540 Soxhlet Extraction

Analyte	Results	RL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Aroclor-1016 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 21:20	KAL
Aroclor-1221 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 21:20	KAL
Aroclor-1232 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 21:20	KAL
Aroclor-1242 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 21:20	KAL
Aroclor-1248 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 21:20	KAL
Aroclor-1254 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 21:20	KAL
Aroclor-1260 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 21:20	KAL
Aroclor-1262 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 21:20	KAL
Aroclor-1268 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 21:20	KAL
Surrogates		% Recovery	Recovery Limits		Flag/Qual				
Decachlorobiphenyl [1]		90.0	30-150					5/9/15 21:20	
Decachlorobiphenyl [2]		88.7	30-150					5/9/15 21:20	
Tetrachloro-m-xylene [1]		81.4	30-150					5/9/15 21:20	
Tetrachloro-m-xylene [2]		84.0	30-150					5/9/15 21:20	

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: Osborn - Gymnasium

Sample Description:

Work Order: 15E0302

Date Received: 5/7/2015

Field Sample #: PCB-W-10 - Floor

Sampled: 5/6/2015 00:00

Sample ID: 15E0302-10

Sample Matrix: Wipe

Polychlorinated Biphenyls with 3540 Soxhlet Extraction

Analyte	Results	RL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Aroclor-1016 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 21:32	KAL
Aroclor-1221 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 21:32	KAL
Aroclor-1232 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 21:32	KAL
Aroclor-1242 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 21:32	KAL
Aroclor-1248 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 21:32	KAL
Aroclor-1254 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 21:32	KAL
Aroclor-1260 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 21:32	KAL
Aroclor-1262 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 21:32	KAL
Aroclor-1268 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 21:32	KAL
Surrogates		% Recovery	Recovery Limits		Flag/Qual				
Decachlorobiphenyl [1]		100	30-150					5/9/15 21:32	
Decachlorobiphenyl [2]		98.9	30-150					5/9/15 21:32	
Tetrachloro-m-xylene [1]		94.2	30-150					5/9/15 21:32	
Tetrachloro-m-xylene [2]		96.8	30-150					5/9/15 21:32	

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: Osborn - Gymnasium

Sample Description:

Work Order: 15E0302

Date Received: 5/7/2015

Field Sample #: PCB-W-11 - Floor

Sampled: 5/6/2015 00:00

Sample ID: 15E0302-11

Sample Matrix: Wipe

Polychlorinated Biphenyls with 3540 Soxhlet Extraction

Analyte	Results	RL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Aroclor-1016 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 21:44	KAL
Aroclor-1221 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 21:44	KAL
Aroclor-1232 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 21:44	KAL
Aroclor-1242 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 21:44	KAL
Aroclor-1248 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 21:44	KAL
Aroclor-1254 [1]	0.84	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 21:44	KAL
Aroclor-1260 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 21:44	KAL
Aroclor-1262 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 21:44	KAL
Aroclor-1268 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 21:44	KAL
Surrogates		% Recovery	Recovery Limits		Flag/Qual				
Decachlorobiphenyl [1]		104	30-150					5/9/15 21:44	
Decachlorobiphenyl [2]		103	30-150					5/9/15 21:44	
Tetrachloro-m-xylene [1]		100	30-150					5/9/15 21:44	
Tetrachloro-m-xylene [2]		102	30-150					5/9/15 21:44	

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: Osborn - Gymnasium

Sample Description:

Work Order: 15E0302

Date Received: 5/7/2015

Field Sample #: PCB-W-12 - Floor

Sampled: 5/6/2015 00:00

Sample ID: 15E0302-12

Sample Matrix: Wipe

Polychlorinated Biphenyls with 3540 Soxhlet Extraction

Analyte	Results	RL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Aroclor-1016 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 21:56	KAL
Aroclor-1221 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 21:56	KAL
Aroclor-1232 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 21:56	KAL
Aroclor-1242 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 21:56	KAL
Aroclor-1248 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 21:56	KAL
Aroclor-1254 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 21:56	KAL
Aroclor-1260 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 21:56	KAL
Aroclor-1262 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 21:56	KAL
Aroclor-1268 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 21:56	KAL
Surrogates		% Recovery	Recovery Limits		Flag/Qual				
Decachlorobiphenyl [1]		98.2	30-150					5/9/15 21:56	
Decachlorobiphenyl [2]		97.6	30-150					5/9/15 21:56	
Tetrachloro-m-xylene [1]		94.1	30-150					5/9/15 21:56	
Tetrachloro-m-xylene [2]		96.5	30-150					5/9/15 21:56	

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: Osborn - Gymnasium

Sample Description:

Work Order: 15E0302

Date Received: 5/7/2015

Field Sample #: PCB-W-13 - Floor

Sampled: 5/6/2015 00:00

Sample ID: 15E0302-13

Sample Matrix: Wipe

Polychlorinated Biphenyls with 3540 Soxhlet Extraction

Analyte	Results	RL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Aroclor-1016 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 22:09	KAL
Aroclor-1221 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 22:09	KAL
Aroclor-1232 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 22:09	KAL
Aroclor-1242 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 22:09	KAL
Aroclor-1248 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 22:09	KAL
Aroclor-1254 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 22:09	KAL
Aroclor-1260 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 22:09	KAL
Aroclor-1262 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 22:09	KAL
Aroclor-1268 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 22:09	KAL
Surrogates		% Recovery	Recovery Limits		Flag/Qual				
Decachlorobiphenyl [1]		99.1	30-150					5/9/15 22:09	
Decachlorobiphenyl [2]		98.2	30-150					5/9/15 22:09	
Tetrachloro-m-xylene [1]		91.6	30-150					5/9/15 22:09	
Tetrachloro-m-xylene [2]		94.0	30-150					5/9/15 22:09	

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: Osborn - Gymnasium

Sample Description:

Work Order: 15E0302

Date Received: 5/7/2015

Field Sample #: PCB-W-14 - Floor

Sampled: 5/6/2015 00:00

Sample ID: 15E0302-14

Sample Matrix: Wipe

Polychlorinated Biphenyls with 3540 Soxhlet Extraction

Analyte	Results	RL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Aroclor-1016 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 22:21	KAL
Aroclor-1221 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 22:21	KAL
Aroclor-1232 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 22:21	KAL
Aroclor-1242 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 22:21	KAL
Aroclor-1248 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 22:21	KAL
Aroclor-1254 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 22:21	KAL
Aroclor-1260 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 22:21	KAL
Aroclor-1262 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 22:21	KAL
Aroclor-1268 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 22:21	KAL
Surrogates		% Recovery	Recovery Limits		Flag/Qual				
Decachlorobiphenyl [1]		98.7	30-150					5/9/15 22:21	
Decachlorobiphenyl [2]		97.6	30-150					5/9/15 22:21	
Tetrachloro-m-xylene [1]		92.1	30-150					5/9/15 22:21	
Tetrachloro-m-xylene [2]		94.6	30-150					5/9/15 22:21	

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: Osborn - Gymnasium

Sample Description:

Work Order: 15E0302

Date Received: 5/7/2015

Field Sample #: PCB-W-15 - Blank

Sampled: 5/6/2015 00:00

Sample ID: 15E0302-15

Sample Matrix: Wipe

Polychlorinated Biphenyls with 3540 Soxhlet Extraction

Analyte	Results	RL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Aroclor-1016 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 22:33	KAL
Aroclor-1221 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 22:33	KAL
Aroclor-1232 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 22:33	KAL
Aroclor-1242 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 22:33	KAL
Aroclor-1248 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 22:33	KAL
Aroclor-1254 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 22:33	KAL
Aroclor-1260 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 22:33	KAL
Aroclor-1262 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 22:33	KAL
Aroclor-1268 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 22:33	KAL
Surrogates		% Recovery	Recovery Limits		Flag/Qual				
Decachlorobiphenyl [1]		95.7	30-150					5/9/15 22:33	
Decachlorobiphenyl [2]		94.9	30-150					5/9/15 22:33	
Tetrachloro-m-xylene [1]		89.4	30-150					5/9/15 22:33	
Tetrachloro-m-xylene [2]		91.9	30-150					5/9/15 22:33	

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

Project Location: Osborn - Gymnasium

Sample Description:

Work Order: 15E0302

Date Received: 5/7/2015

Field Sample #: PCB-W-16 - Blank

Sampled: 5/6/2015 00:00

Sample ID: 15E0302-16

Sample Matrix: Wipe

Polychlorinated Biphenyls with 3540 Soxhlet Extraction

Analyte	Results	RL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Aroclor-1016 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 22:45	KAL
Aroclor-1221 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 22:45	KAL
Aroclor-1232 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 22:45	KAL
Aroclor-1242 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 22:45	KAL
Aroclor-1248 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 22:45	KAL
Aroclor-1254 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 22:45	KAL
Aroclor-1260 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 22:45	KAL
Aroclor-1262 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 22:45	KAL
Aroclor-1268 [1]	ND	0.20	µg/Wipe	1		SW-846 8082A	5/8/15	5/9/15 22:45	KAL
Surrogates		% Recovery	Recovery Limits		Flag/Qual				
Decachlorobiphenyl [1]		98.8	30-150					5/9/15 22:45	
Decachlorobiphenyl [2]		98.6	30-150					5/9/15 22:45	
Tetrachloro-m-xylene [1]		92.7	30-150					5/9/15 22:45	
Tetrachloro-m-xylene [2]		95.1	30-150					5/9/15 22:45	

Sample Extraction Data**Prep Method: SW-846 3540C-SW-846 8082A**

Lab Number [Field ID]	Batch	Initial [Wipe]	Final [mL]	Date
15E0302-01 [PCB-W-01 - Side A Wall]	B121329	1.00	10.0	05/08/15
15E0302-02 [PCB-W-02 - Side A Wall]	B121329	1.00	10.0	05/08/15
15E0302-03 [PCB-W-03 - Side B Wall]	B121329	1.00	10.0	05/08/15
15E0302-04 [PCB-W-04 - Side B Wall]	B121329	1.00	10.0	05/08/15
15E0302-05 [PCB-W-05 - Side C Wall]	B121329	1.00	10.0	05/08/15
15E0302-06 [PCB-W-06 - Side C Wall]	B121329	1.00	10.0	05/08/15
15E0302-07 [PCB-W-07 - Side D Wall]	B121329	1.00	10.0	05/08/15
15E0302-08 [PCB-W-08 - Side D Wall]	B121329	1.00	10.0	05/08/15
15E0302-09 [PCB-W-09 - Floor]	B121329	1.00	10.0	05/08/15
15E0302-10 [PCB-W-10 - Floor]	B121329	1.00	10.0	05/08/15
15E0302-11 [PCB-W-11 - Floor]	B121329	1.00	10.0	05/08/15
15E0302-12 [PCB-W-12 - Floor]	B121329	1.00	10.0	05/08/15
15E0302-13 [PCB-W-13 - Floor]	B121329	1.00	10.0	05/08/15
15E0302-14 [PCB-W-14 - Floor]	B121329	1.00	10.0	05/08/15
15E0302-15 [PCB-W-15 - Blank]	B121329	1.00	10.0	05/08/15
15E0302-16 [PCB-W-16 - Blank]	B121329	1.00	10.0	05/08/15

39 Spruce Street * East Longmeadow, MA 01028 * FAX 413/525-6405 * TEL. 413/525-2332

QUALITY CONTROL

Polychlorinated Biphenyls with 3540 Soxhlet Extraction - Quality Control

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
---------	--------	-----------------	-------	-------------	---------------	------	-------------	-----	-----------	-------

Batch B121329 - SW-846 3540C

Blank (B121329-BLK1)

Prepared: 05/08/15 Analyzed: 05/09/15

Aroclor-1016	ND	0.20	µg/Wipe							
Aroclor-1016 [2C]	ND	0.20	µg/Wipe							
Aroclor-1221	ND	0.20	µg/Wipe							
Aroclor-1221 [2C]	ND	0.20	µg/Wipe							
Aroclor-1232	ND	0.20	µg/Wipe							
Aroclor-1232 [2C]	ND	0.20	µg/Wipe							
Aroclor-1242	ND	0.20	µg/Wipe							
Aroclor-1242 [2C]	ND	0.20	µg/Wipe							
Aroclor-1248	ND	0.20	µg/Wipe							
Aroclor-1248 [2C]	ND	0.20	µg/Wipe							
Aroclor-1254	ND	0.20	µg/Wipe							
Aroclor-1254 [2C]	ND	0.20	µg/Wipe							
Aroclor-1260	ND	0.20	µg/Wipe							
Aroclor-1260 [2C]	ND	0.20	µg/Wipe							
Aroclor-1262	ND	0.20	µg/Wipe							
Aroclor-1262 [2C]	ND	0.20	µg/Wipe							
Aroclor-1268	ND	0.20	µg/Wipe							
Aroclor-1268 [2C]	ND	0.20	µg/Wipe							
Surrogate: Decachlorobiphenyl	1.65		µg/Wipe	2.00		82.6	30-150			
Surrogate: Decachlorobiphenyl [2C]	1.63		µg/Wipe	2.00		81.3	30-150			
Surrogate: Tetrachloro-m-xylene	1.76		µg/Wipe	2.00		87.8	30-150			
Surrogate: Tetrachloro-m-xylene [2C]	1.74		µg/Wipe	2.00		87.2	30-150			

LCS (B121329-BS1)

Prepared: 05/08/15 Analyzed: 05/09/15

Aroclor-1016	0.41	0.20	µg/Wipe	0.500		82.8	40-140			
Aroclor-1016 [2C]	0.43	0.20	µg/Wipe	0.500		85.9	40-140			
Aroclor-1260	0.47	0.20	µg/Wipe	0.500		93.1	40-140			
Aroclor-1260 [2C]	0.45	0.20	µg/Wipe	0.500		90.3	40-140			
Surrogate: Decachlorobiphenyl	1.89		µg/Wipe	2.00		94.3	30-150			
Surrogate: Decachlorobiphenyl [2C]	1.85		µg/Wipe	2.00		92.4	30-150			
Surrogate: Tetrachloro-m-xylene	1.81		µg/Wipe	2.00		90.4	30-150			
Surrogate: Tetrachloro-m-xylene [2C]	1.80		µg/Wipe	2.00		90.2	30-150			

LCS Dup (B121329-BSD1)

Prepared: 05/08/15 Analyzed: 05/09/15

Aroclor-1016	0.35	0.20	µg/Wipe	0.500		70.0	40-140	16.8	30	
Aroclor-1016 [2C]	0.34	0.20	µg/Wipe	0.500		67.4	40-140	24.1	30	
Aroclor-1260	0.38	0.20	µg/Wipe	0.500		76.2	40-140	20.0	30	
Aroclor-1260 [2C]	0.37	0.20	µg/Wipe	0.500		73.2	40-140	20.9	30	
Surrogate: Decachlorobiphenyl	1.50		µg/Wipe	2.00		75.2	30-150			
Surrogate: Decachlorobiphenyl [2C]	1.48		µg/Wipe	2.00		74.1	30-150			
Surrogate: Tetrachloro-m-xylene	1.48		µg/Wipe	2.00		73.9	30-150			
Surrogate: Tetrachloro-m-xylene [2C]	1.51		µg/Wipe	2.00		75.7	30-150			

**IDENTIFICATION SUMMARY
FOR SINGLE COMPONENT ANALYTES**

PCB-W-11 - Floor

SW-846 8082A

Lab Sample ID: 15E0302-11 Date(s) Analyzed: 05/09/2015 05/09/2015

Instrument ID (1): Instrument ID (2):

GC Column (1): ID: (mm) GC Column (2): ID: (mm)

ANALYTE	COL	RT	RT WINDOW		CONCENTRATION	%D
			FROM	TO		
Aroclor-1254	1	0.00	0.00	0.00	0.84	
	2	0.00	0.00	0.00	0.83	1.4

**IDENTIFICATION SUMMARY
FOR SINGLE COMPONENT ANALYTES**
SW-846 8082A

LCS

Lab Sample ID: B121329-BS1 Date(s) Analyzed: 05/09/2015 05/09/2015

Instrument ID (1): _____ Instrument ID (2): _____

GC Column (1): _____ ID: _____ (mm) GC Column (2): _____ ID: _____ (mm)

ANALYTE	COL	RT	RT WINDOW		CONCENTRATION	%D
			FROM	TO		
Aroclor-1016	1	0.00	0.00	0.00	0.41	
	2	0.00	0.00	0.00	0.43	4
Aroclor-1260	1	0.00	0.00	0.00	0.47	
	2	0.00	0.00	0.00	0.45	3

FLAG/QUALIFIER SUMMARY

- * QC result is outside of established limits.
- † Wide recovery limits established for difficult compound.
- ‡ Wide RPD limits established for difficult compound.
- # Data exceeded client recommended or regulatory level

Percent recoveries and relative percent differences (RPDs) are determined by the software using values in the calculation which have not been rounded.

No results have been blank subtracted unless specified in the case narrative section.

CERTIFICATIONS

Certified Analyses included in this Report

Analyte	Certifications
---------	----------------

No certified Analyses included in this Report

The CON-TEST Environmental Laboratory operates under the following certifications and accreditations:

Code	Description	Number	Expires
AIHA	AIHA-LAP, LLC	100033	02/1/2016
MA	Massachusetts DEP	M-MA100	06/30/2015
CT	Connecticut Department of Public Health	PH-0567	09/30/2015
NY	New York State Department of Health	10899 NELAP	04/1/2016
NH-S	New Hampshire Environmental Lab	2516 NELAP	02/5/2016
RI	Rhode Island Department of Health	LAO00112	12/30/2015
NC	North Carolina Div. of Water Quality	652	12/31/2015
NJ	New Jersey DEP	MA007 NELAP	06/30/2015
FL	Florida Department of Health	E871027 NELAP	06/30/2015
VT	Vermont Department of Health Lead Laboratory	LL015036	07/30/2015
WA	State of Washington Department of Ecology	C2065	02/23/2016
ME	State of Maine	2011028	06/9/2015
VA	Commonwealth of Virginia	460217	12/14/2015
NH-P	New Hampshire Environmental Lab	2557 NELAP	09/6/2015



con-test[®] Phone: 413-525-2332
 ANALYTICAL LABORATORY Fax: 413-525-6405
 Email: info@contestlabs.com
 www.contestlabs.com

CHAIN OF CUSTODY RECORD

39 Spruce Street
 East Longmeadow, MA 01028

Company Name: **AMC Environmental** Telephone: **203-378-5020**

Address: **P.O. Box 423** Project # _____

Stratford, CT 06615 Client PO# _____

Attention: **Jason Pringle**

Project Location: **Osborn - Gymnasium**

Sampled By: _____

Project Proposal Provided? (for billing purposes)
 yes proposal date _____

DATA DELIVERY (check all that apply)
 FAX EMAIL WEBSITE

Fax # _____

Email: **results@amcenviro.com**

Format: PDF EXCEL GIS OTHER

"Enhanced Data Package"

Con-Test Lab ID <small>(laboratory use only)</small>	Client Sample ID / Description	Collection		Conc Code
		Beginning Date/Time	Ending Date/Time	
01	PCB-W-01 - Side A Wall	05/06/15		
02	PCB-W-02 Side A Wall	05/06/15		
03	PCB-W-03 Side B Wall	05/06/15		
04	PCB-W-04 Side B Wall	05/06/15		
05	PCB-W-05 Side C Wall	05/06/15		
06	PCB-W-06 Side C Wall	05/06/15		
07	PCB-W-07 Side D Wall	05/06/15		
08	PCB-W-08 Side D Wall	05/06/15		
09	PCB-W-09 Floor	05/06/15		
10	PCB-W-10 Floor	05/06/15		

Comments: _____

Please use the following codes to let Con-Test know if a specific sample may be high in concentration in Matrix/Conc. Code Box:
 H - High; M - Medium; L - Low; C - Clean; U - Unknown

Requisitioned by: (signature) *Jason Pringle* Date/Time: *5/7/15*

Received by: (signature) *Paul Reed* Date/Time: *5/7/15 14:30*

Requisitioned by: (signature) *Paul Reed* Date/Time: *5/7/15 13:45*

Received by: (signature) *Jason Pringle* Date/Time: *5/7/15 17:45*

Turnaround Time: *3.3*

TURNAROUND TIME STARTS AT 9:00 A.M. THE DAY AFTER SAMPLE RECEIPT UNLESS THERE ARE QUESTIONS ON YOUR CHAIN. IF THIS FORM IS NOT FILLED OUT COMPLETELY OR IS INCORRECT, TURNAROUND TIME WILL NOT START UNTIL ALL QUESTIONS ARE ANSWERED BY OUR CLIENT.

Is your project MCP or RCP?

MCP Form Required
 RCP Form Required
 MA State DW Form Required PWSID # _____

Massachusetts: _____
 Connecticut: *<1PPM*
 Other: _____

NECAC & AIHA Certified
WBE/DBE Certified

39 Spruce St.
 East Longmeadow, MA. 01028
 P: 413-525-2332
 F: 413-525-6405
 www.contestlabs.com



Sample Receipt Checklist

CLIENT NAME: AMC Environmental RECEIVED BY: SDL DATE: 5/7/15

- 1) Was the chain(s) of custody relinquished and signed? Yes No No CoC Included
- 2) Does the chain agree with the samples? Yes No
 If not, explain: _____
- 3) Are all the samples in good condition? Yes No
 If not, explain: _____
- 4) How were the samples received:
 On Ice Direct from Sampling Ambient In Cooler(s)

Were the samples received in Temperature Compliance of (2-6°C)? Yes No N/A
 Temperature °C by Temp blank _____ Temperature °C by Temp gun 3.3

- 5) Are there Dissolved samples for the lab to filter? Yes No
 Who was notified _____ Date _____ Time _____
- 6) Are there any RUSH or SHORT HOLDING TIME samples? Yes No
 Who was notified _____ Date _____ Time _____

7) Location where samples are stored: 19
 Permission to subcontract samples? Yes No
 (Walk-in clients only) if not already approved
 Client Signature: _____

- 8) Do all samples have the proper Acid pH: Yes No N/A
- 9) Do all samples have the proper Base pH: Yes No N/A
- 10) Was the PC notified of any discrepancies with the CoC vs the samples: Yes No N/A

Containers received at Con-Test

	# of containers			# of containers
1 Liter Amber			8 oz amber/clear jar	
500 mL Amber			4 oz amber/clear jar	
250 mL Amber (8oz amber)			2 oz amber/clear jar	16 wipes
1 Liter Plastic			Plastic Bag / Ziploc	
500 mL Plastic			SOC Kit	
250 mL plastic			Non-ConTest Container	
40 mL Vial - type listed below			Perchlorate Kit	
Colisure / bacteria bottle			Flashpoint bottle	
Dissolved Oxygen bottle			Other glass jar	
Encore			Other	

Laboratory Comments:

40 mL vials: # HCl _____ # Methanol _____ # Bisulfate _____ # DI Water _____ # Thiosulfate _____ Unpreserved _____	Time and Date Frozen:
--	-----------------------

Doc# 277

Rev. 4 August 2013

Login Sample Receipt Checklist
 (Rejection Criteria Listing - Using Sample Acceptance Policy)
 Any False statement will be brought to the attention of Client

Question	Answer (True/False)	Comment
	T/F/NA	
1) The cooler's custody seal, if present, is intact.	NA	
2) The cooler or samples do not appear to have been compromised or tampered with.	T	
3) Samples were received on ice.	T	
4) Cooler Temperature is acceptable.	T	
5) Cooler Temperature is recorded.	T	
6) COC is filled out in ink and legible.	T	
7) COC is filled out with all pertinent information.	T	
8) Field Sampler's name present on COC.	T	
9) There are no discrepancies between the sample IDs on the container and the COC.	T	
10) Samples are received within Holding Time.	T	
11) Sample containers have legible labels.	T	
12) Containers are not broken or leaking.	T	
13) Air Cassettes are not broken/open.	NA	
14) Sample collection date/times are provided.	T	
15) Appropriate sample containers are used.	T	
16) Proper collection media used.	T	
17) No headspace sample bottles are completely filled.	T	
18) There is sufficient volume for all requested analyses, including any requested MS/MSDs.	T	
19) Trip blanks provided if applicable.	NA	
20) VOA sample vials do not have head space or bubble is <6mm (1/4") in diameter.	NA	
21) Samples do not require splitting or compositing.	T	

Doc #277 Rev. 4 August 2013

Who notified of False statements?

Log-In Technician Initials: JDL

Date/Time:

Date/Time: 5/7/15 1745