



Asbestos Abatement Monitoring Report  
for  
Riverfield Elementary School  
1625 Mill Plain Road  
Fairfield, Connecticut

Prepared  
for  
Fairfield Public Schools  
501 Kings Highway  
Fairfield, CT 06824

December 24 to 30, 2014

EnviroMed Project IH-14-338

470 Murdock Ave., Meriden, CT 06450  
(203) 238-4846 • facsimile (203) 238-4243

## TABLE OF CONTENTS

1. Project Narrative
2. Daily Log Reports
3. Sign In Sheets
4. Air Monitoring Sheets
5. Certificate of Visual Inspection

## 1. Project Narrative

### Overview

From December 24<sup>th</sup> to 30<sup>th</sup>, 2014, the contractor performed asbestos abatement at the Riverfield Elementary School, 1625 Mill Plain Road, Fairfield, Connecticut.

#### Contractor

A.A.I. S.

State License # 000017

802 Boston Post Road, West Haven, CT

The scope of work included the removal of asbestos containing materials in accordance with specification.

The following state licensed project monitor performed daily site monitoring during the contractors abatement work.

<u>Asbestos Project Monitor</u>	<u>State License Number</u>
Souleymane Doumbia	000693

#### Re-Occupancy Visual Inspection and Air Clearance Testing

EnviroMed Services state licensed asbestos project monitor performed visual inspections in accordance with the State of Connecticut Department of Public Health Criteria for re-occupancy following asbestos abatement. The contractor and project monitor visually inspected each work area and all surfaces, including pipes, beams, ledges, walls, ceiling and floor, decontamination unit, sheet plastic, etc.) and found no dust, debris or residue.

Clearance air sampling was performed in regulated work areas inside the building. All air samples collected were found to meet the State of Connecticut Department of Public Health re-occupancy clearance criteria for completion of asbestos abatement.

## 2. Daily Log Reports

470 Murdock Avenue  
Meriden, CT 06450  
(203) 238-4846  
(203) 238-4243

EMS Job #: 14-14-338

Date: 12-24-14

Client/State Job #:

DPW #:

Client: FAIRFIELD PUBLIC SCHOOL

Worksite: RIVERFIELD ELEMENTARY SCHOOL

Address: 1625 HILL PLAIN ROAD, FAIRFIELD, CT

Time	Comments
7:00	EMS GET ON THE JOB SITE, THE WORKERS FROM AATS ARE ON SITE. MEET WITH OSCAR THE SUPERVISOR FROM AATS TO DISCUSS THE WORK AREA PREPARATION.
8:00	THE WORKERS FROM AATS ARE MOBILIZING THE EQUIPMENT INSIDE THE WORK AREA.
9:00	EMS SET UP, PRE-CALIBRATE THE AIR SAMPLING PUMPS AND START MONITORING PERMETER AIR SAMPLES.
10:00	EMS SET UP THE MICROSCOPE TO READ THE BACKGROUND AIR SAMPLES. THE WORKERS ARE DOING WORK AREA PREPARATION.
11:30	EMS POST CALIBRATE AND CHANGE THE CASSETTES ON THE AIR SAMPLING PUMPS. THE WORK AREA PREPARATION CONTINUE
12:00	WORKERS GO ON LUNCH BREAK.
12:30	WORKERS ARE BACK TO WORK.
13:00	WORK AREA PREPARATION CONTINUE
14:30	EMS POST CALIBRATE AND STOP THE AIR SAMPLING PUMPS.
15:30	EMS LEAVE THE JOB SITE AS THE CONTRACTOR HAS LEFT.

Signature: *Paulina Ramirez*

470 Murdock Avenue  
 Meriden, CT 06450  
 (203) 238-4846  
 (203) 238-4243

EMS Job #: 14-14-338

Date: 12-26-14

Client/State Job #:

DPW #:

Client: FAIRFIELD PUBLIC SCHOOL

Worksite: REVERFIELD ELEMENTARY SCHOOL

Address: 1625 MILL PLAIN RD, FAIRFIELD, CT. 06425

Time	Comments
7:00	EMS GET TO THE JOB SITE. AHS WORKERS ARE ON SITE DOING WORK AREA PREPARATION.
7:40	EMS SET UP, PRE-CALIBRATE THE AIR SAMPLING PUMPS AND START RUNNING PERMETRER AIR SAMPLES.
8:30	OSCAR THE SUPERVISOR FROM AHS CALL FOR PRE-ABATEMENT VISUAL INSPECTION ON CONTAINMENT #1. A FULL DISCON UNIT IS IN PLACE AND FULLY OPERATIONAL, A NEGATIVE AIR MACHINE IS RUNNING INSIDE THE CONTAINMENT WALL, CEILING POLY AND ALL CRITICALS ARE INTACT THE WORK AREA MEET PRE-ABATEMENT VISUAL INSPECTION CRITERIA.
10:00	THE WORKERS ARE DOING AIR ABATEMENT INSIDE CONTAINMENT #1.
11:40	EMS POST CALIBRATE AND CHANGE THE Cassettes ON THE AIR SAMPLING PUMPS. THE WORKERS ARE DOING AIR ABATEMENT INSIDE CONTAINMENT #1 AND PREPARING TO WORK WORK AREA.
12:30	THE WORKERS FROM AHS WENT TO LUNCH BREAK.
13:45	OSCAR THE SUPERVISOR FROM AHS CALL FOR PRE-ABATEMENT VISUAL INSPECTION ON CONTAINMENT #2. THE CONTAINMENT #2 MEET PRE-ABATEMENT VISUAL INSPECTION CRITERIA.
15:00	THE WORKERS ARE FINISHING THE WORK AREA DOING REMOVAL.
16:45	OSCAR CALL FOR FINAL VISUAL INSPECTION ON CONTAINMENT #1. THE FINAL VISUAL INSPECTION FAILED.
7:30	EMS LEAVE THE JOB SITE AS THE WORKERS ARE LEAVING.

In nature: *[Signature]*



470 Murdock Avenue  
 Meriden, CT 06450  
 (203) 238-4846  
 (203) 238-4243

EMS Job #: 14-14-388

Date: 12-27-14

Client/State Job #:

DPW #:

Client: FAIRFIELD PUBLIC SCHOOL

Worksite: RIVERFIELD ELEMENTARY SCHOOL

Address: 1625 MILL PLAIN RD, FAIRFIELD, CT.

Time	Comments
14:00	THE CONTRACTOR CALL FOR PRE-ABATEMENT VISUAL INSPECTION ON THE CONTAINMENT IN THE CUSTODIAN ROOM.
14:45	THE CONTRACTOR CALL FOR FINAL VISUAL INSPECTION ON CONTAINMENT #3, THE BOILER ROOM TUNNELS. THE FINAL VISUAL INSPECTION IS PASS.
15:00	THE CONTRACTOR CALL FOR FINAL VISUAL INSPECTION ON CONTAINMENT #2 INSIDE THE RESTROOMS. THE FINAL VISUAL INSPECTION IS PASS.
15:45	EMS SET UP, PRE-CALIBRATE THE AIR SAMPLING PUMPS AND START RUNNING F.A.C - P.C.M AIR SAMPLES INSIDE CONTAINMENT #2 RESTROOMS.
16:15	EMS SET UP, PRE-CALIBRATE THE AIR SAMPLING PUMPS AND START RUNNING F.A.C - P.C.M AIR SAMPLES INSIDE CONTAINMENT #3, BOILER ROOM TUNNELS.
17:20	THE CONTRACTOR CALL FOR FINAL VISUAL INSPECTION ON THE CONTAINMENT IN THE CUSTODIAN ROOM (#4) THE FINAL VISUAL INSPECTION IS PASS.
18:10	EMS SET UP, PRE-CALIBRATE THE AIR SAMPLING PUMPS AND START RUNNING F.A.C - P.C.M AIR SAMPLES INSIDE CONTAINMENT #4.
19:30	EMS POST-CALIBRATE AND STOP THE F.A.C - P.C.M AIR SAMPLES INSIDE CONTAINMENT #4.
20:00	EMS SET UP THE MICROSCOPE, PREPARED TO READ THE SAMPLES.

Signature: *Anthony J. ...*



470 Murdock Avenue  
 Meriden, CT 06450  
 (203) 238-4846  
 (203) 238-4243

EMS Job #: 11-14-338

Date: 12-27-14

Client/State Job #:

DPW #:

Client: FAIRFIELD PUBLIC SCHOOL

Worksite: REVERFIELD ELEMENTARY SCHOOL

Address: 1625 MELL PLAIN RD, FAIRFIELD, CT

Time	Comments
7:00	EMS GET TO THE JOB SITE. THE WORKERS FROM MAIS ARE ON SITE
8:30	OSHA. THE SUPERVISOR FROM MAIS CALL FOR FINAL VISUAL INSPECTION ON CONTAINMENT #1. SOME BLACK FLOORING MATERIAL HAS BEEN LEFT BEHIND ALONG THE WALL. AND EXPOSED WORK PROOFING CHALK HAS BEEN ENCAPSULATED TO BE RETROVED WITH THE PHASE II. I TALK TO JOHN LUBY THE PROJECT MANAGER FROM ENVIROTECH. HE SAID THAT THE FLOORING MATERIAL WILL BE TESTED AND REMOVED IF NECESSARY WITH THE PHASE II.
10:00	THE CONTRACTOR CALLS FOR PRE-ABATEMENT VISUAL INSPECTION ON THE CONTAINMENT INSIDE THE BOLLER ROOM. THE PRE-ABATEMENT VISUAL INSPECTION IS PASS.
10:20	EMS POST CALIBRATE AND STOP THE BACKGROUND AIR SAMPLING PUMPS.
10:40	EMS SET UP, PRE-CALIBRATE THE AIR SAMPLING PUMPS AND START RUNNING F.A.C.-TE M AIR SAMPLERS ON CONTAINMENT #1.
12:00	THE WORKERS GO ON LUNCH BREAK.
12:30	WORKERS ARE BACK TO WORK BEING ACN ABATEMENT.
13:30	EMS POST CALIBRATE AND STOP THE F.A.C.-TE M AIR SAMPLING PUMPS FROM CONTAINMENT #1. THE WORKERS ARE DOING FINAL CLEANING INSIDE CONTAINMENT #2 AND AIR REMOVAL INSIDE CONTAINMENT #3.

Signature:





### 3. Sign In Sheets



EnviroMed Services, Inc.

470 Murdock Avenue, Box 13  
 Meriden, CT 06450  
 (203) 238-4846  
 Fax (203) 238-4243

SIGN-IN SHEET, JOB SITE

EMS Job #: LH-14-338 Date: 12-26-14 Client/State Job #: \_\_\_\_\_

Client: PRIMFIELD PUBLIC SCHOOL Address: \_\_\_\_\_ DPW # \_\_\_\_\_

Worksite: RIVERFIELD ELEM. SCHOOL Address: 625 MILL PLACE RD, FARMFIELD, CT

Name (Print)	Representing	Time In	Out to lunch	In from lunch	Time left
Dennis Clonchar	AALS	7:00	12:30	13:00	17:30
Oscar Hernandez					
Eric Syk					
Robbie Eason					
Chris Cagnano					
Walter Biene					
Carlos Ortega					
Franklin Guallo					
German Rivera					
Jesse Meneche					
Wladimir Torres					
SOULEY MAHE DOUTHRIA	ETS	7:00	12:00	12:30	17:30

Signature: \_\_\_\_\_



UnviroMed Services, Inc.

470 Murdock Avenue, Box 13  
Meriden, CT 06450  
(203) 238-4846  
Fax (203) 238-4243

SIGN-IN SHEET, JOB SITE

EMS Job # TH-14-338 Date: 12-27-14 Client/State Job #: \_\_\_\_\_ DPW# \_\_\_\_\_

Client: FAIRFIELD PUBLIC SCHOOL Address: \_\_\_\_\_

Worksite: RIVERFIELD ELEM. SCHOOL Address: 1625 MELL PLAIN RD, FAIRFIELD, CT

Name (Print)	Representing	Time In	Out to lunch	In from lunch	Time left
Dennis Cloninger	AAIS	7:10			18:00
Chris Caggiano					
Wladimir Torres					
Walter Bueno					
Franklin Guallo					
Robbie Fason					
Carlos Ortega					
Jose Moracho					
Gasparin Rivera					
Eric S. Cyt.					
Oscar Hernandez					
Al Canrad					

Signature: Loulymaire G. Jarama



**EnviroMed Services, Inc.**

470 Murdock Avenue  
Meriden, CT 06450  
(203) 238-4846  
Fax (203) 238-4243

**SIGN-IN SHEET, CONTAINMENT**

Information required by the State of Connecticut Regulation Section 19a-352a-4(b)(7)

EMS Job #: 14-14-338 Date: 12-26-14 Client/State Job #:

DPW #:

Client: \_\_\_\_\_ Address: \_\_\_\_\_

Worksite: RIVERFIELD, ELEM. SCHOOL Address: 1625 MILL PLAIN RD, FAIRFIELD, CT

Name (Print)		Representing	Time In	Time Out	Time In	Time Out	Time In	Time Out	*T	M
Print: <u>Franklin Guallo</u>		<u>AAIS</u>	<u>9:30</u>	<u>11:50</u>	<u>12:45</u>	<u>17:25</u>				
Sign: _____										
Print: <u>Carlos Ontiveros</u>		<u>AAIS</u>	<u>9:30</u>	<u>11:55</u>	<u>12:45</u>	<u>17:23</u>				
Sign: _____										
Print: <u>Robbie Eason</u>		<u>AAIS</u>	<u>9:30</u>	<u>11:52</u>	<u>12:45</u>	<u>17:24</u>				
Sign: _____										
Print: <u>Oscar Hernandez</u>		<u>AAIS</u>			<u>17:15</u>	<u>17:26</u>				
Sign: _____										
Print: <u>SOULEYMANES BOUMATA</u>		<u>EMS</u>	<u>17:00</u>	<u>17:15</u>						
Sign: <u>Souleymanes Boumata</u>										
Print: _____										
Sign: _____										
Print: _____										
Sign: _____										

\*T indicates the possession of employee Training Records

**EnviroMed Services, Inc.**

470 Murdock Avenue  
 Meriden, CT 06450  
 (203) 238-4845  
 Fax (203) 238-4243

**SIGN-IN SHEET, CONTAINMENT**

Information required by the State of Connecticut Regulation Section 19a-332a-4(b)(7)

EMS Job #: 1A-14-338 Date: 12-26-14 Client/State Job #: \_\_\_\_\_ DPW #: \_\_\_\_\_

Client: \_\_\_\_\_ Address: \_\_\_\_\_

Worksite: RIVERFIELD ELEM. SCHOOL

Address: 625 MILL PLAIN RD. FAIRFIELD, CT

	Name (Print)	Representing	Time		Time		Time		Time		*T	*M
			In	Out	In	Out	In	Out	In	Out		
Print:	<u>Wladimir Torres</u>											
Sign:	<u><del>Wladimir Torres</del></u>											
Print:	<u>Walter Bieme</u>											
Sign:	<u>Walter Bieme</u>											
Print:	_____											
Sign:	_____											
Print:	_____											
Sign:	_____											
Print:	_____											
Sign:	_____											

\*T indicates the possession of employee Training Record

EnviroMed Services, Inc.

470 Murdock Avenue  
Meriden, CT 06450  
(203) 238-4846  
Fax (203) 238-4243

**SIGN-IN SHEET, CONTAINMENT**

Information required by the State of Connecticut Regulation Section 19a-332a-4(b)(7)

EMS Job #: 114-14-388 Date: 12-27-14 Client/State Job #:

DPW #:

Client: FARFIELD PUBLIC SCHOOL Address:

Worksite: ALVERFIELD ELEM SCHOOL Address: 1625 MILL PLAZA RD, FARFIELD, CT

Name (Print)	Representing	Time		Time		Time		Time		*T	*M
		In	Out	In	Out	In	Out	In	Out		
Print: <u>Chris Caggiano</u>	AAIS	2:00	5:20 3:45								
Sign: <u>[Signature]</u>											
Print: <u>Rachel Casan</u>	AAIS	2:00	5:20								
Sign: <u>[Signature]</u>											
Print: <u>Eric Cyr</u>	AAIS	4:00	5:20								
Sign: <u>[Signature]</u>											
Print: <u>SOWLEY TRUHE DONOVAN</u>	EMS	5:25	5:45								
Sign: <u>[Signature]</u>											
Print: _____											
Sign: _____											
Print: _____											
Sign: _____											
Print: _____											
Sign: _____											

\*T indicates the possession of employee Training Record

Enviromed Services, Inc.

470 Murdock Avenue  
Meriden, CT 06450  
(203) 238-4846  
Fax (203) 238-4243

**SIGN-IN SHEET, CONTAINMENT**

Information required by the State of Connecticut Regulation Section 19a-332a-4(b)(7)

EMS Job #: 14-14-388 Date: 12-27-14 Client/State Job #:

Client: FARFIELD PUBLIC SCHOOL Address: \_\_\_\_\_ DPW #:

Worksite: BEVERFIELD ELEM. SCHOOL Address: 1625 TILIA PLAZA RD, FAIRFIELD CT

Name (Print)		Representing	Time In	Time Out	Time In	Time Out	Time In	Time Out	*T	*M
Print: <u>SOULEYTHANE DOUNBIA</u>										
Sign: _____		<u>EMS</u>	<u>14:55</u>	<u>15:05</u>						
Print: <u>Carlos Artego</u>										
Sign: <u>Carlos Artego</u>										
Print: <u>Franklin Quallo</u>										
Sign: <u>Franklin Quallo</u>										
Print: <u>German Rivera</u>										
Sign: _____										
Print: _____										
Sign: _____										
Print: _____										
Sign: _____										

\*T indicates the possession of employee Training Records

**Enviromed Services, Inc.**

470 Murdock Avenue  
Meriden, CT 06450  
(203) 238-4846  
Fax (203) 238-4243

**SIGN-IN SHEET, CONTAINMENT**

Information required by the State of Connecticut Regulation Section 19a-332a-4(b)(7)

EMS Job #: 117-14-338 Date: 12-27-14 Client/State Job #: \_\_\_\_\_ DPW #: \_\_\_\_\_

Client: FAIRFIELD PUBLIC SCHOOL Address: \_\_\_\_\_

Worksite: REVERFELD ELEM. SCHOOL Address: 1625 MILL PLAIN RD, FAIRFIELD, CT

Name (Print)		Representing	Time In	Time Out	Time In	Time Out	Time In	Time Out	*T	*M
Print: <u>Walter Benz</u>										
Sign: <u>Walter Benz</u>		<u>FAFAS</u>	<u>7:10</u>	<u>9:00</u>	<u>9:16</u>	<u>11:59</u>	<u>12:32</u>	<u>3:15</u>		
Print: <u>Wladimir Torres</u>										
Sign: <u>Wladimir Torres</u>		<u>FAFAS</u>	<u>7:10</u>	<u>9:00</u>	<u>9:16</u>	<u>11:59</u>	<u>12:33</u>	<u>3:16</u>		
Print: <u>SOULEYMANE DOUMBIA</u>										
Sign: <u>Souleymane Doumbia</u>		<u>EHS</u>	<u>15:15</u>	<u>15:00</u>						
Print: _____										
Sign: _____										
Print: _____										
Sign: _____										
Print: _____										
Sign: _____										

\*T indicates the possession of employee Training Records

#### 4. Air Monitoring Sheets

# AIR MONITORING SUMMARY

**EnviroMed Services, Inc.**

470 Murdock Avenue  
 Meriden, CT 06450  
 (203) 238-4846  
 Fax (203) 238-4243

NVLAP Lab Code #1514      CT Lab #PH-0571      MA Cert. #AA000049

Filter Size	Filter Area	Microscope Field Area
25 mm	385 mm <sup>2</sup>	0.00785 mm <sup>2</sup>

EMS Job # 14-338      Client Job #:

DPW #: 162

Worksite: Fairfield Elementary School      Address: 1625 Mill Plain Rd. Fairfield, CT

Sampled By: Sallyanne Donatelli      Date: 12-24-14

Analyzed By: Sallyanne Donatelli      Date: 12-24-14

Average Daily Blank:

**Project Information**

A = Area Sample, P = Personal Sample, B = Below Quantification Limit, PW = Prep. Work, C = Clearance, R = Removal, BG = Background

Sample No.	Sample Location	Sampling Time (min)		Flow Rate (liters/min.)		Total Volume	Fibers/Field	Fibers/cc	Quantification Limit	Comments
		Start	Stop	Begin	End					
1	Hallway	8:55	11:35	8.0	8.0	1280	9/100	20,004	0.004	A, B
2	INSENE GR 717	8:58	11:38	8.0	8.0	1280	6/100	20,004	0.004	A, B
3	INSENE GR 717	9:00	11:00	8.0	8.0	1280	7/100	20,004	0.004	A, B
4	BY BACK DOOR	9:05	11:05	8.0	8.0	1280	15/100	0.006	0.004	A, B
5	F. B	-	-	-	-	-	0/100	-	-	A, B
6	F. B	-	-	-	-	-	0/100	-	-	

Analyzed By: Sallyanne Donatelli      Approved By: \_\_\_\_\_

# EnviroMed Services, Inc.

470 Murdock Avenue  
Meriden, CT 06450  
(203) 238-4846  
Fax (203) 238-4243

NVLAP Lab Code #1514

CT Lab #PH-0571

MA Cert. #AA000049

# AIR MONITORING SUMMARY

Filter Size	Filter Area	Microscope Field Area
25 mm	385 mm <sup>2</sup>	0.00785 mm <sup>2</sup>

EMS Job #: DA-14-338 Client Job #: \_\_\_\_\_ DPW #: \_\_\_\_\_

Worksites: RIVERFIELD ELEMENT SCHOOL Address: 1625 TULLY ROAD, FAIRFIELD, CT

Sampled By: Christy Anne Sturman Date: 12-24-14 Analyzed By: Christy Anne Sturman Date: 12-27-14

Average Daily Blank: \_\_\_\_\_

### Project Information

A = Area Sample, P = Personal Sample, B = Below Quantification Limit, PW = Prep. Work, C = Clearance, R = Removal, BG = Background

Sample No.	Sample Location	Sampling Time (min)		Flow Rate (liters/min.)		Total Volume	Fibers/Field	Fibers/cc	Quantification Limit	Comments
		Start	Stop	Begin	End					
5	F.B.						0/100	—	0.003	A, B
6	F.B.						0/100	—	0.003	A, B
7	Hallway	11:55	14:55	8.0	8.0	1440	5/100	<0.003	0.003	A, B
8	INSIDE GYM	11:58	14:58	8.0	8.0	1440	7/100	<0.003	0.003	A, B
9	INSIDE GYM	11:40	14:40	8.0	8.0	1440	6/100	<0.003	0.003	A, B
10	BY BACK DOOR	11:43	14:43	8.0	8.0	1440	9/100	<0.003	0.003	A, B

Approved By: \_\_\_\_\_

Analyzed By: Christy Anne Sturman



Filter Size	Filter Area	Microscope Field Area
25 mm	385 mm <sup>2</sup>	0.00785 mm <sup>2</sup>

EMS Job # JH-14-338 Client Job #: \_\_\_\_\_ DPW #: \_\_\_\_\_

Worksite: ALBERTFIELD ELEMENTARY SCHOOL Address: 1625 NWL PRADO RD, FAIRFIELD, CT

Sampled By: Lois Lawrence Date: 12-26-14 Analyzed By: Lois Lawrence Date: 12-27-14

**Project Information**

A = Area Sample, P = Personal Sample, B = Below Quantification Limit, PW = Prep. Work, C = Clearance, R = Removal, BG = Background

Sample No.	Sample Location	Sampling Time (min)		Flow Rate (liters/min.)		Total Volume	Fibers/Field	Fibers/cc	Quantification Limit	Comments
		Start	Stop	Begin	End					
1	HALLWAY	8:40	11:40	8.0	8.0	1440	16/100	0.005	0.003	A, B
2	INSIDE 647	8:42	11:42	8.0	8.0	1440	11/100	0.004	0.003	A, B
3	INSIDE 647	8:44	11:44	8.0	8.0	1440	7/100	0.003	0.003	A, B
4	BY BACK DOOR	8:46	11:46	8.0	8.0	1440	17/100	0.005	0.003	A, B
5	F.B.	—	—	—	—	—	0/100	—	0.003	A, B
6	F.B.	—	—	—	—	—	0/100	—	0.003	A, B

Client: \_\_\_\_\_ Average Daily Blank: \_\_\_\_\_

Analyzed By: Lois Lawrence Approved By: \_\_\_\_\_

# EnviroMed Services, Inc.

470 Murdock Avenue  
Meriden, CT 06450  
(203) 238-4846  
Fax (203) 238-4243

# AIR MONITORING SUMMARY

NVLAP Lab Code #1514 CT Lab #PH-0571 MA Cert. #AA000049

Filter Size	Filter Area	Microscope Field Area
25 mm	385 mm <sup>2</sup>	0.00785 mm <sup>2</sup>

EMS Job #: PH-14-358 Client Job #: \_\_\_\_\_ DPW #: \_\_\_\_\_

Worksite: ALVERFIELD ELEM. SCHOOL Address: 1625 TILK PLAZA RD, FARMFIELD, CT

Sampled By: Josephine D'Amico Date: 12-16-14 Analyzed By: Josephine D'Amico Date: 12-27-14

### Project Information

A = Area Sample, P = Personal Sample, B = Below Quantification Limit, PW = Prep. Work, C = Clearance, R = Removal, BG = Background

Sample No.	Sample Location	Sampling Time (min)		Flow Rate (liters/min.)		Total Volume	Fibers/Field	Fibers/cc	Quantification Limit	Comments
		Start	Stop	Total	Avg.					
5	F.B						/	-	0.003	A, R
6	F.B						/	-	0.003	A, R
7	FRONT OF DECK	1140	1540	240	8.0	1920	/	<0.003	0.003	A, R
8	INSIDE GYR	1142	1542	240	8.0	1920	/	<0.003	0.003	A, R
9	FRONT OF DECK	1144	1544	240	8.0	1920	/	<0.003	0.003	A, R
10	BY BACK DOOR	1146	1546	240	8.0	1920	/	0.003	0.003	A, R

Analyzed By: Josephine D'Amico

Approved By: \_\_\_\_\_

# EnviroMed Services, Inc.

470 Murdock Avenue  
Meriden, CT 06450  
(203) 238-4846  
Fax (203) 238-4243

# AIR MONITORING SUMMARY

NVLAP Lab Code #1514 CT Lab #PH-0571 MA Cert. #AA000049

Filter Size	Filter Area	Microscope Field Area
25 mm	385 mm <sup>2</sup>	0.00785 mm <sup>2</sup>

EMS Job # 14-14-338 Client Job #: \_\_\_\_\_ DPW #: \_\_\_\_\_  
 Worksite: ROVERFIELD ELEM. SCHOOL Address: 1625 MILL PLAIN RD. FAIRFIELD, CT  
 Sampled By: Joselynne Sturmbay Date: 12-27-14 Analyzed By: Joselynne Sturmbay Date: 12-27-14  
 Average Daily Blank: \_\_\_\_\_

### Project Information

A = Area Sample, P = Personal Sample, B = Below Quantification Limit, PW = Prep. Work, C = Clearance, R = Removal, BG = Background

Sample No.	Sample Location	Sampling Time (min)		Flow Rate (liters/min.)			Total Volume	Fibers/Field	Fibers/cc	Quantification Limit	Comments
		Start	Stop	Begin	End	Avg.					
1	FRONT OF DECK 2	8:38	10:08	8.0	8.0	8.0	800	5/100	<0.006	0.006	A, R
2	INSIDE GYM	8:40	10:20	8.0	8.0	8.0	800	8/100	<0.006	0.006	A, R
3	FRONT OF DECK 1	8:42	10:22	8.0	8.0	8.0	800	7/100	<0.006	0.006	A, R
4	BY BACK DOOR	8:44	10:24	8.0	8.0	8.0	800	9/100	<0.006	0.006	A, R
5	F. B.	---	---	---	---	---	---	0/100	---	0.006	A, R
6	F. B.	---	---	---	---	---	---	0/100	---	0.006	A, R

Analyzed By: Joselynne Sturmbay Approved By: \_\_\_\_\_

**EnviroMed Services, Inc.**

470 Murdock Avenue  
Meriden, CT 06450  
(203) 238-4846  
Fax (203) 238-4243

**AIR MONITORING SUMMARY**

NVLAP Lab Code #1514

CT Lab #PH-0571

MA Cert. #AA000049

Filter Size	Filter Area	Microscope Field Area
25 mm	385 mm <sup>2</sup>	0.00785 mm <sup>2</sup>

EMS Job #: 14-16-38 Client Job #: \_\_\_\_\_ DPW #: \_\_\_\_\_  
 Worksite: RIVERFIELD ELEM. SCHOOL Address: 1625 MDL PLAZA RD, FAIRFIELD, CT  
 Sampled By: Jacobymare Drumbo Date: 12-27-14 Analyzed By: Jacobymare Drumbo Date: 12-27-14  
 Average Daily Blank: \_\_\_\_\_

**Project Information**

A = Area Sample, P = Personal Sample, B = Below Quantification Limit, PW = Prep. Work, C = Clearance, R = Removal, BG = Background

Sample No.	Sample Location	Sampling Time (min)		Flow Rate (liters/min.)		Total Volume	Fibers/Field	Fibers/cc	Quantification Limit	Comments
		Start	Stop	Begin	End					
5	F.B.						0/100	<0.004	0.004	A, C
6	F.B.						0/100	<0.004	0.004	A, C
7	INSIDE WORK AREA	15 <sup>30</sup>	17 <sup>10</sup>	15.0	15.0	1200	5/100	<0.004	0.004	A, C
8	INSIDE WORK AREA	15 <sup>51</sup>	17 <sup>11</sup>	15.0	15.0	1200	3/100	<0.004	0.004	A, C
9	INSIDE WORK AREA	15 <sup>52</sup>	17 <sup>12</sup>	15.0	15.0	1200	4/100	<0.004	0.004	A, C
10	INSIDE WORK AREA	15 <sup>53</sup>	17 <sup>13</sup>	15.0	15.0	1200	3/100	<0.004	0.004	A, C
11	INSIDE WORK AREA	15 <sup>54</sup>	17 <sup>14</sup>	15.0	15.0	1200	6/100	<0.004	0.004	A, C

Analyzed By: Jacobymare Drumbo

Approved By: \_\_\_\_\_

# EnviroMed Services, Inc.

470 Murdock Avenue  
Meriden, CT 06450  
(203) 238-4846  
Fax (203) 238-4243

# AIR MONITORING SUMMARY

NVLAP Lab Code #1514 CT Lab #PH-0571 MA Cert. #AA000049

Filter Size	Filter Area	Microscope Field Area
25 mm	385 mm <sup>2</sup>	0.00785 mm <sup>2</sup>

EMS Job #: 14-14-388 Client Job #: DPW #: Client: Average Daily Blank:

Worksite: RIVERFIELD BLEN. SCHOOL Address: 1625 DELL PLANO RD, BRIDGEFIELD, CT

Sampled By: Ruby Moore Sampling Date: 12-27-14 Analyzed By: Loreley Moore Sampling Date: 12-27-14

## Project Information

A = Area Sample, P = Personal Sample, B = Below Quantification Limit, PW = Prep. Work, C = Clearance, R = Removal, BG = Background

Sample No.	Sample Location	Sampling Time (min)		Flow Rate (liters/min.)		Total Volume	Fibers/Field	Fibers/cc	Quantification Limit	Comments
		Start	Stop	Total	Avg.					
17	F. B.						0/100	20.004	0.004	A, C
18	F. B.						0/100	20.004	0.004	A, C
19	INSIDE WORK AREA	18 <sup>10</sup>	19 <sup>00</sup>	80	15.5	1240	3/100	20.004	0.004	A, C
20	I. W. A	18 <sup>14</sup>	19 <sup>01</sup>	80	15.5	1240	5/100	20.004	0.004	A, C
21	I. W. A	18 <sup>12</sup>	19 <sup>02</sup>	80	15.5	1240	4/100	20.004	0.004	A, C
22	I. W. A	18 <sup>13</sup>	19 <sup>03</sup>	80	15.5	1240	2/100	20.004	0.004	A, C
23	I. W. A	18 <sup>14</sup>	19 <sup>04</sup>	80	15.5	1240	3/100	20.004	0.004	A, C

Analyzed By: *Loreley Moore* *Sampling*

Approved By:

**EnviroMed Services, Inc.**  
 470 Murdock Avenue  
 Meriden, CT 06450  
 (203) 238-4846  
 Fax (203) 238-4243

**AIR MONITORING SUMMARY**

NVLAP Lab Code #1514 CT Lab #PH-0571 MA Cert. #AA000049

Filter Size	Filter Area	Microscope Field Area
25 mm	385 mm <sup>2</sup>	0.00785 mm <sup>2</sup>

EMS Job #: 11-14-38 Client Job #: \_\_\_\_\_ DPW #: \_\_\_\_\_ Client: \_\_\_\_\_

Worksites: RIVERFIELD ELEM. SCHOOL Address: 1625 MILL PLAIN RD. FAIRFIELD, CT  
 Sampled By: Sobuzman, Dumbriv Date: 12-27-14 Analyzed By: Sobuzman, Dumbriv Date: 12-27-14

**Project Information**

Average Daily Blank: \_\_\_\_\_

A = Area Sample, P = Personal Sample, B = Below Quantification Limit, PW = Prep. Work, C = Clearance, R = Removal, BG = Background

Sample No.	Sample Location	Sampling Time (min)		Flow Rate (liters/min.)	Total Volume	Fibers/Field	Fibers/cc	Quantification Limit	Comments
		Start	Stop						
12	INSIDE MIDWAY PARK	16 <sup>12</sup>	17 <sup>44</sup>	90	1350	7/100	<0.004	0.004	A, C
13	I.W. A	16 <sup>13</sup>	17 <sup>43</sup>	90	1350	8/100	<0.004	0.004	A, C
14	I.W. A	16 <sup>14</sup>	17 <sup>44</sup>	90	1350	5/100	<0.004	0.004	A, C
15	I.W. A	16 <sup>15</sup>	17 <sup>45</sup>	90	1350	6/100	<0.004	0.004	A, C
16	I.W. A	16 <sup>16</sup>	17 <sup>46</sup>	90	1350	9/100	<0.004	0.004	A, C
17	F. B	—	—	—	—	0/100	<0.004	0.004	A, C
18	F. B	—	—	—	—	0/100	—	0.004	A, C

Analyzed By: Sobuzman, Dumbriv

Approved By: \_\_\_\_\_



# EMSL Analytical, Inc.

29 North Plains Highway, Unit # 4, Wallingford, CT 06492  
Phone/Fax: 203-284-5948 / (203) 284-5978  
<http://www.EMSL.com> [wallingfordlab@emsl.com](mailto:wallingfordlab@emsl.com)

EMSL Order: 241405097  
CustomerID: ENVM50  
CustomerPO: CK110536/110527  
ProjectID:

Attn: **John Luby**  
**EnviroMed Services, Inc.**  
**470 Murdock Avenue**  
**Meriden, CT 06450**

Phone: (203) 238-4846  
Fax: (203) 238-4243  
Received: 12/29/14 11:00 AM  
Analysis Date: 12/29/2014  
Collected: 12/29/2014

Project: RIVERFIELD SCHO

## Test Report: Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Appendix A to Subpart E

Sample	Location	Volume (Liters)	Area Analyzed (mm <sup>2</sup> )	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration	
						≥ 0.5μ < 5μ	≥ 5μ		(S/mm <sup>2</sup> )	(S/cc)
1 241405097-0001	INSIDE WORK AREA	1235.00	0.0660	0	None Detected			0.0047	<15.00	<0.0047
2 241405097-0002	INSIDE WORK AREA	1235.00	0.0660	0	None Detected			0.0047	<15.00	<0.0047
3 241405097-0003	INSIDE WORK AREA	1235.00	0.0660	0	None Detected			0.0047	<15.00	<0.0047
4 241405097-0004	INSIDE WORK AREA	1235.00	0.0660	0	None Detected			0.0047	<15.00	<0.0047
5 241405097-0005	INSIDE WORK AREA	1235.00	0.0660	0	None Detected			0.0047	<15.00	<0.0047

Analyst(s)

William Shedrawy (5)

Gloria V. Oriol, Laboratory Manager  
or other approved signatory

EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. This report must not be used to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government. Results reported in both structures/cm<sup>3</sup> and structures/mm<sup>2</sup> are dependent on the volume of air sampled and measured by non-laboratory personnel are not the responsibility of EMSL and are not covered by the laboratory's NVLAP accreditation. Samples received in good condition unless otherwise noted. Estimated accuracy, precision and uncertainty data available upon request.

Samples analyzed by EMSL Analytical, Inc. Wallingford, CT NVLAP Lab Code 200700-3, CT PH-0322, MA AA000191, RI AAL-108T3, VT AL357101

Initial report from 12/29/2014 15:52:17



EMSL ANALYTICAL, INC.  
LABORATORY PRODUCTS TRAINING

Asbestos Chain of Custody  
EMSL Order Number (Lab Use Only):

241405097

Wallingford, CT 06492  
PHONE: (203) 284-5948  
FAX: (203) 284-5978

Company Name : Enviromed Services		EMSL Customer ID:	
Street: 470 Murdock Avenue		City: Meriden	State/Province: CT
Zip/Postal Code: 06450	Country: United States	Telephone #: 203-238-4846	Fax #: 203-238-4243
Report To (Name): John Luby		Please Provide Results: <input type="checkbox"/> Fax <input checked="" type="checkbox"/> Email	
Email Address: jluby@enviromedservices.com		Purchase Order:	
Project Name/Number: Riverfield Scho		EMSL Project ID (Internal Use Only):	
U.S. State Samples Taken: CT		CT Samples: <input type="checkbox"/> Commercial/Taxable <input checked="" type="checkbox"/> Residential/Tax Exempt	

EMSL-Bill to:  Same  Different - If Bill to is Different note instructions in Comments\*  
Third Party Billing requires written authorization from third party

Turnaround Time (TAT) Options\* - Please Check  
 3 Hour  6 Hour  24 Hour  48 Hour  72 Hour  96 Hour  1 Week  2 Week  
 \*For TEM Air 3 hr through 6 hr, please call ahead to schedule. There is a premium charge for 3 Hour TEM AHERA or EPA Level II TAT. You will be asked to sign an authorization form for this service. Analysis completed in accordance with EMSL's Terms and Conditions located in the Analytical Price Guide.

PCM - Air <input type="checkbox"/> Check if samples are from NY <input type="checkbox"/> NIOSH 7400 <input type="checkbox"/> w/ OSHA 8hr. TWA PLM - Bulk (reporting limit) <input type="checkbox"/> PLM EPA 600/R-93/116 (<1%) <input type="checkbox"/> PLM EPA NOB (<1%) Point Count <input type="checkbox"/> 400 (<0.25%) <input type="checkbox"/> 1000 (<0.1%) Point Count w/Gravimetric <input type="checkbox"/> 400 (<0.25%) <input type="checkbox"/> 1000 (<0.1%) <input type="checkbox"/> NYS 198.1 (friable in NY) <input type="checkbox"/> NYS 198.6 NOB (non-friable-NY) <input type="checkbox"/> NYS 198.8 SOF-V <input type="checkbox"/> NIOSH 9002 (<1%)	TEM - Air <input type="checkbox"/> 4-4.5hr TAT (AHERA only) <input checked="" type="checkbox"/> AHERA 40 CFR, Part 763 <input type="checkbox"/> NIOSH 7402 <input type="checkbox"/> EPA Level II <input type="checkbox"/> ISO 10312 TEM - Bulk <input type="checkbox"/> TEM EPA NOB <input type="checkbox"/> NYS NOB 198.4 (non-friable-NY) <input type="checkbox"/> Chatfield SOP <input type="checkbox"/> TEM Mass Analysis-EPA 600 sec. 2.5 TEM - Water: EPA 100.2 Fibers >10µm <input type="checkbox"/> Waste <input type="checkbox"/> Drinking All Fiber Sizes <input type="checkbox"/> Waste <input type="checkbox"/> Drinking	TEM- Dust <input type="checkbox"/> Microvac - ASTM D 5755 <input type="checkbox"/> Wipe - ASTM D6480 <input type="checkbox"/> Carpet Sonication (EPA 600/J-93/167) Soil/Rock/Vermiculite* <input type="checkbox"/> PLM CARB 435 - A (0.25% sensitivity) <input type="checkbox"/> PLM CARB 435 - B (0.1% sensitivity) <input type="checkbox"/> TEM CARB 435 - B (0.1% sensitivity) <input type="checkbox"/> TEM CARB 435 - C (0.01% sensitivity) <input type="checkbox"/> TEM Qual. via Filtration Technique <input type="checkbox"/> TEM Qual. via Drop-Mount Technique *Can not accept New York State Loose Fill Vermiculite Samples Other: <input type="checkbox"/>
--	--	--

Check For Positive Stop - Clearly Identify Homogenous Group Filter Pore Size (Air Samples):  0.8µm  0.45µm

Samplers Name: \_\_\_\_\_ Samplers Signature: \_\_\_\_\_

Sample #	Sample Description	Volume/Area (Air) HA # (Bulk)	Date/Time Sampled
1	INSIDE WORK AREA	1235	12-29-14-AM
2	INSIDE WORK AREA	1235	12-29-14-AM
3	INSIDE WORK AREA	1235	12-29-14-AM
4	INSIDE WORK AREA	1235	12-29-14-AM
5	INSIDE WORK AREA	1235	12-29-14-AM
6	OUTSIDE WORK AREA	1235	12-29-14-AM
7	OUTSIDE WORK AREA	1235	12-29-14-AM

Client Sample # (s): 1-13 Total # of Samples: 13  
 Relinquished (Client): *Billymore Dumbis* Date: 12-29-14 Time: AM  
 Received (Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Comments/Special Instructions: PLEASE CALL JOHN LUBY FOR RESULTS (860) 214 3528  
 Paid by check 000  
 Bill To: Enviromed Services, 470 Murdock Avenue, Meriden, CT, 06450, United States  
 Attention: Cynthia McQuiter Phone: 203-238-4846 Email: CMcQuiter@enviromedservices.com Purchase Order

RECEIVED  
 DEC 29 2014  
 By: *[Signature]* 11:00am *walk*





## 5. Certificate of Visual Inspection

470 Murdock Avenue
Meriden, CT 06450
(203) 238-4846
Fax (203) 238-4243

CONTAINMENT #1

EMS Job # 11-14-338 Date: 12-27-14 Client/State Job #: DPW #:

Worksite: RIVERFIELD BLISS SCHOOL Address: 1625 MTN PLAZA RD, RIVERFIELD, CT

The Contractor hereby certifies that he has visually inspected the work area (all surfaces including pipes, beams, ledges, walls, ceiling and floor, decontamination unit, sheet plastic, etc.) and has found no dust, debris or residue.

by: (Signature) Dennis McLean Date: 12/27/14
(Print Name) Dennis McLean
(Print Title) Supervisor

PROJECT ADMINISTRATOR CERTIFICATION

\* SUSPECT FLOORING MATERIAL AND WALL MATERIAL PROPOSED TO BE REMOVE WITH PASTE IT.

The on-site EnviroMed representative and DPH representative (if applicable) hereby certifies that they have accompanied the Contractor on his visual inspection and verifies that this inspection has been thorough and to the best of their knowledge and belief, the contractor's certification above is true and honest one.

by: (Signature) Souleymane Dumbia Date: 12-27-14
(Print Name) SOULEY MANE DUMBIA
(Print Title) SENIOR INDUSTRIAL HYGIENIST

by: (Signature) Date:
(Print Name)
(Print Title)

Sampled By: SD Date: 12-29-14 Analyzed By: EMSL Date: 12-29-14

Table with 6 columns: Sample #, Total Min., Flow Rate (liters/min), Total Vol. (liters), Structures/mm2, Detection limit. Rows 1-5 show 1235.00 liters, none detected, and 0.0047 detection limit.

The above information is transcribed from the Air Monitoring Summary Sheets located at the end of this report.

470 Murdock Avenue  
 Meriden, CT 06450  
 (203) 238-4846  
 Fax (203) 238-4243

CONTAMINANT # 2 - RESTROOMS

EMS Job # 14-14-388 Date: 12-27-14 Client/State Job #: \_\_\_\_\_ DPW #: \_\_\_\_\_

Worksite: REVERE JELD ELEM. SCHOOL Address: 1625 HILL PLAIN RD, FAIRFIELD, CT

The Contractor hereby certifies that he has visually inspected the work area (all surfaces including pipes, beams, ledges, walls, ceiling and floor, decontamination unit, sheet plastic, etc.) and has found no dust, debris or residue.

by: (Signature) Dennis McConner Date: 12-27-14  
 (Print Name) Dennis McConner  
 (Print Title) Supervisor

PROJECT ADMINISTRATOR CERTIFICATION

The on-site EnviroMed representative and DPH representative (if applicable) hereby certifies that they have accompanied the Contractor on his visual inspection and verifies that this inspection has been thorough and to the best of their knowledge and belief, the contractor's certification above is true and honest one.

by: (Signature) Souleymane Dounbia Date: 12-27-14  
 (Print Name) SOULEYMANE DOUNBIA  
 (Print Title) SENIOR INDUSTRIAL HYGIENIST

by: (Signature) Dennis McConner Souleymane Dounbia Date: 12-27-14  
 (Print Name) Dennis McConner Souleymane Dounbia  
 (Print Title) Supervisor Senior Industrial Hygienist

Sampled By: Souleymane Dounbia Date: 12-27-14 Analyzed By: Souleymane Dounbia Date: 12-27-14

Sample #	Total Min.	Flow Rate (liters/min)	Total Vol. (liters)	Structures/mm <sup>2</sup>	Detection limit
7	80	15.0	1200	<0.004	0.004
8	80	15.0	1200	<0.004	0.004
9	80	15.0	1200	<0.004	0.004
10	80	15.0	1200	<0.004	0.004
11	80	15.0	1200	<0.004	0.004
Average Blank Correction used for the above samples:					

The above information is transcribed from the Air Monitoring Summary Sheets located at the end of this report.

**EnviroMed Services, Inc. CERTIFICATION OF VISUAL INSPECTION**

470 Murdock Avenue  
 Meriden, CT 06450  
 (203) 238-4846  
 Fax (203) 238-4243

CONTAINMENT #3, BOILER ROOM TUNNELS

EMS Job # 11-14-388 Date: 12-21-14 Client/State Job #: \_\_\_\_\_ DPW #: \_\_\_\_\_

Worksite: RIVERFIELD ELEM. SCHOOL Address: 1625 HILL PLAIN RD, FAIRFIELD, CT

The Contractor hereby certifies that he has visually inspected the work area (all surfaces including pipes, beams, ledges, walls, ceiling and floor, decontamination unit, sheet plastic, etc.) and has found no dust, debris or residue.

by: (Signature) Dennis M O'Connor Date: 12-27-14  
 (Print Name) Dennis M O'Connor  
 (Print Title) Supervisor

**PROJECT ADMINISTRATOR CERTIFICATION**

The on-site EnviroMed representative and DPH representative (if applicable) hereby certifies that they have accompanied the Contractor on his visual inspection and verifies that this inspection has been thorough and to the best of their knowledge and belief, the contractor's certification above is true and honest one.

by: (Signature) Soumya Dumbia Date: 12-27-14  
 (Print Name) SOUMYA DUMBIA  
 (Print Title) SENIOR INDUSTRIAL HYGIENIST

by: (Signature) Dennis M O'Connor Date: 12-27-14  
 (Print Name) Dennis M O'Connor  
 (Print Title) Supervisor

Sampled By: Soumya Dumbia Date: 12-27-14 Analyzed By: Soumya Dumbia Date: 12-27-14

Sample #	Total Min.	Flow Rate (liters/min)	Total Vol. (liters)	Fibers / cc	Quantification limit
12	90	15.0	1350	<0.004	0.004
13	90	15.0	1350	<0.004	0.004
14	90	15.0	1350	<0.004	0.004
15	90	15.0	1350	<0.004	0.004
16	90	15.0	1350	<0.004	0.004
Average Blank Correction used for the above samples:					

The above information is transcribed from the Air Monitoring Summary Sheets located at the end of this report.

EnviroMed Services, Inc.

CERTIFICATION OF VISUAL INSPECTION

470 Murdock Avenue
Meriden, CT 06450
(203) 238-4846
Fax (203) 238-4243

CONTAINMENT # 4, CUSTODIAN ROOM

EMS Job #11-14-388 Date: 12-27-14 Client/State Job #: DPW #:

Worksite: RIVERFIELD ELEM. SCHOOL Address: 1625 MILL PLAIN RD, FARMINGTON, CT

The Contractor hereby certifies that he has visually inspected the work area (all surfaces including pipes, beams, ledges, walls, ceiling and floor, decontamination unit, sheet plastic, etc.) and has found no dust, debris or residue.

by: (Signature) Dennis M. O'Connell Date: 12-27-14
(Print Name) DENNIS M O'CONNOR
(Print Title) SUPERVISOR

PROJECT ADMINISTRATOR CERTIFICATION

The on-site EnviroMed representative and DPH representative (if applicable) hereby certifies that they have accompanied the Contractor on his visual inspection and verifies that this inspection has been thorough and to the best of their knowledge and belief, the contractor's certification above is true and honest one.

by: (Signature) Souleymane Doumbia Date: 12-27-14
(Print Name) SOULEYMANE DOUMBIA
(Print Title) SENIOR INDUSTRIAL HYGIENIST

by: (Signature) Date:
(Print Name)
(Print Title)

Sampled By: Souleymane Doumbia Date: 12-27-14 Analyzed By: Souleymane Doumbia Date: 12-27-14

Table with 6 columns: Sample #, Total Min., Flow Rate (liters/min), Total Vol. (liters), Fibers / cc, Quantification limit. Rows 19-23 show consistent data with flow rate 15.5 and fibers/cc 20.004.

The above information is transcribed from the Air Monitoring Summary Sheets located at the end of this report.



**EMSL Analytical, Inc.**

29 North Plains Highway, Unit # 4, Wallingford, CT 06492

Phone/Fax: 203-284-5948 / (203) 284-5978

<http://www.EMSL.com>

[wallingfordlab@emsl.com](mailto:wallingfordlab@emsl.com)

EMSL Order:	241405091
CustomerID:	ENVM50
CustomerPO:	
ProjectID:	

Attn: <b>John Luby</b> <b>EnviroMed Services, Inc.</b> <b>470 Murdock Avenue</b> <b>Meriden, CT 06450</b>	Phone: (203) 238-4846 Fax: (203) 238-4243 Received: 12/28/14 11:40 AM Analysis Date: 12/28/2014 Collected: 12/27/2014
Project: 1H-14-388	

**Test Report: Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)  
Performed by EPA 40 CFR Part 763 Appendix A to Subpart E**

Sample	Location	Volume (Liters)	Area Analyzed (mm <sup>2</sup> )	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration	
						≥ 0.5μ < 5μ	≥ 5μ		(S/mm <sup>2</sup> )	(S/cc)
1 241405091-0001	INSIDE WORK AREA	1216.00			Overloaded					
2 241405091-0002	INSIDE WORK AREA	1216.00			Overloaded					
3 241405091-0003	INSIDE WORK AREA	1200.00			Overloaded					
4 241405091-0004	INSIDE WORK AREA	1200.00			Overloaded					
5 241405091-0005	INSIDE WORK AREA	1200.00			Overloaded					

Analyst(s)  
Kristin Lopez (5)

Gloria V. Oriol, Laboratory Manager  
or other approved signatory

EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. This report must not be used to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government. Results reported in both structures/cm3 and structures/mm2 are dependent on the volume of air sampled and measured by non-laboratory personnel are not the responsibility of EMSL and are not covered by the laboratory's NVLAP accreditation. Samples received in good condition unless otherwise noted. Estimated accuracy, precision and uncertainty data available upon request.

Samples analyzed by EMSL Analytical, Inc. Wallingford, CT NVLAP Lab Code 200700-0, CT PH-0322, MA AA000191, RI AAL-108T3, VT AL357101

Initial report from 12/28/2014 13:27:32